



Weekly Inspection Checklist

For Dangerous Waste Container Accumulation Area

For the Month of _____, _____

Mark answers Yes or No below

Week 1	Week 2	Week 3	Week 4	Week 5
--------	--------	--------	--------	--------

	Date	Time	Inspector's Printed Name AND Signature
Week 1	/ /		
Week 2	/ /		
Week 3	/ /		
Week 4	/ /		
Week 5	/ /		

- Are all drums and containers marked or labeled as hazardous waste (or “waste pending analysis”)?
- Are all drums and containers marked with the risks associated with the waste?
- Are all containers (excluding satellite containers) marked with the accumulation start date?
- Are any drums near or exceeding the LQG 90-day or MQG 180-day timeframe?
- Are all drum labels visible and readable?
- Are all containers closed?
- Are all drums and containers in good condition?
- Are any drums leaking?
- Is there 30 inches of aisle space between rows of containers?

Containment

- Is the secondary containment free of cracks or other failures?
- Are sumps clean and free of contamination, spills, leaks, and standing water?

Safety Equipment

This section is not required for weekly inspections but will meet some of the general facility inspection requirements.

- Are fire extinguishers charged?
- Are spill kits stocked?
- Is the first aid cabinet stocked?
- Is the emergency shower and eye wash station functioning properly?
- Are the emergency communication devices operating properly?
- Is emergency response information posted near all communication devices? (MQG only)

Comments: Describe the actions taken to correct each deficiency noted above, and note date each action was taken.

Note: Container inspections that are required “at least weekly” in the dangerous waste regulations must be conducted at least once every seven days and not more than six calendar days between inspection dates. Reference the Dangerous Waste Regulations, Chapter 173-303 Washington Administrative Code (WAC) for more information, specifically, WAC 173-303-200(1)(b) and by reference 630(6).